


# **BROCKVILLE DRINKING WATER SYSTEM**



---

**BROCKVILLE**

---

CITY OF THE 1000 ISLANDS

## **2023 ANNUAL WATER QUALITY REPORT**

P. Raabe, P. Eng., Director of Engineering and Infrastructure  
C. Sluytman, Supervisor – Water Systems Division

DATE: February 28, 2024

## **EXECUTIVE SUMMARY**

The City of Brockville's Water Systems Division is pleased to provide the 2023 Annual Drinking Water Quality Report. The purpose of this report is to keep the public and Council informed regarding the quality of the City's drinking water and the performance and maintenance of our water treatment and distribution systems.

The City of Brockville is dedicated to delivering a clean, safe, reliable, drinking water supply to the consumer while remaining compliant with all regulatory requirements. Achievement of those commitments is supported by risk-based process evaluation, staff competency, effective communications, and appropriate contingency / incident response measures. The managers and employees of the City of Brockville who are directly involved in the production and delivery of safe drinking water are committed to and share in the responsibilities for implementing, maintaining, and contributing to the continual improvement of the Drinking Water Quality Management System. The water delivered to the consumers in the City of Brockville and a portion in the Township of Elizabethtown-Kitley continues to be safe, meeting all drinking water quality regulatory standards.

This Annual Drinking Water Quality Report is prepared in accordance with the Municipal Drinking Water Licence, Drinking Water Works Permit for the Brockville Drinking Water System and Ontario Regulation 170/03, Section 11 and Schedule 22. Included with this report are analytical data, plant flow, adverse water quality incidents and corrective action resolutions, as well as a process flow schematic of the facility.

## TABLE OF CONTENTS

|   | PAGE # |
|---|--------|
| Executive Summary   | 2      |
| Table of Contents   | 3      |
| List of Acronyms & Definitions                                | 4      |
| <br>  |        |
| 1. INTRODUCTION   | 5      |
| 2. LEGISLATED REQUIREMENTS                                    | 5      |
| 2.1 Drinking-Water Systems Regulation (O. Reg. 170/03)        |        |
| 2.2 Summary of Regulatory Requirements                        |        |
| 3. ANNUAL WATER QUALITY SUMMARY FOR 2023                      | 7      |
| 3.1 Water Quality Data  |        |
| 4. BROCKVILLE DRINKING WATER SYSTEM                           | 14     |
| 4.1 Water System Description                                  |        |
| 4.2 2023 Flow Summary   |        |
| 4.3 Adverse Test Results                                      |        |
| 4.4 Operator Certification                                    |        |
| 4.5 Capital Program   |        |
| 5. TOWNSHIP OF ELIZABETHTOWN-KITLEY WATER DISTRIBUTION SYSTEM | 19     |
| 5.1 Water System Description                                  |        |
| 5.2 Adverse Test Results                                      |        |
| 5.3 Historical Flow Results                                   |        |
| 6. CONCLUSION   | 21     |
| 7. KEY CONTACTS   | 21     |
| <br>  |        |
| <u>APPENDICES</u>   |        |
| Appendix A Water Treatment Flow Schematic                     | 22     |
| Appendix B 2023 Capital Program                               | 23     |
| Appendix C 2023 Flow Report                                   | 24-26  |
| Appendix D 2023 Water Loss Report Brockville DWS              | 27     |
| Appendix E 2023 Water Loss Report Elizabethtown-Kitley WD     | 28     |

## **LIST OF ACRONYMS & DEFINITIONS**

|                   |   |
|-------------------|---|
| AWQI              | Adverse Water Quality Incidents   |
|                   | Examples of adverse water results: <ul style="list-style-type: none"> <li>▪ An analytical result that exceeds a health-based water quality standards</li> <li>▪ Any evidence that disinfection may not have been effective</li> <li>▪ Low chlorine residuals</li> </ul> |
| C of A            | Certificate of Approval   |
| CFU               | colony forming units  |
| CGSB              | Canadian General Standards Board  |
| DWQMS             | Drinking Water Quality Management Standard  |
| GUDI              | groundwater under the direct influence of surface water   |
| L/s               | litres per second   |
| m <sup>3</sup> /d | cubic metres per day  |
| mg/L              | milligrams per litre  |
| mL                | milliliter  |
| ML/d              | Mega (million) litres per day   |
| MECP              | Ministry of the Environment, Conservation and Parks (Ontario)   |
| MOH               | Medical Officer of Health   |
| PVC               | Poly Vinyl Chloride   |
| O. Reg.           | Ontario Regulation  |
| PTTW              | Permit to Take Water  |
| R.R.O.            | Revised Regulations Ontario (1990)  |
| SCADA             | Supervisory Control and Data Acquisition  |
| SDWA              | Safe Drinking Water Act, 2002   |
| WTP               | Water Treatment Plant   |

## **1. INTRODUCTION**

This Annual Water Quality Report is for the period from January 1<sup>st</sup> to December 31<sup>st</sup>, 2023 and includes reporting for both the municipal drinking water treatment and distribution systems that the City of Brockville owns and operates and the water distribution system that the Township of Elizabethtown-Kitley owns and the City of Brockville operates.

This report contains three different reports required for the City of Brockville and the Elizabethtown-Kitley Drinking Water Systems:

- Section 11 Annual Report, as per Section 11 of O. Reg. 170/03
- Summary report as per Schedule 22 of O. Reg. 170/03
- Summary of the raw water values that were submitted to the Ministry of the Environment, Conservation and Parks under O. Reg. 387/04 Water Taking & Transfer

This annual report is available to the public at no charge. Users of this drinking water system have been notified that this annual report is available by placing a notice on the City of Brockville's website. The 2023 Annual Water Quality Report is available at the following locations:

- City of Brockville's website - [www.brockville.com](http://www.brockville.com)
- City of Brockville – Public Library
- City of Brockville – Customer Service office, City Hall
- City of Brockville – Water Systems Division, 20 Rivers Ave., 613-342-8772 ext. 5512
- Township of Elizabethtown-Kitley's website - <http://www.ektwp.ca>
- Township of Elizabethtown-Kitley's Municipal Office – 6544 New Dublin Road, Addison

## **2. LEGISLATED REQUIREMENTS**

### **2.1 Drinking-Water Systems Regulation (O. Reg. 170/03)**

Under Schedule 22 of the Drinking Water Systems Regulation (O. Reg. 170/03), Summary Reports for Municipalities, annual reports to the owners of large municipal residential systems and small municipal systems are required. The summary report must be submitted no later than March 31<sup>st</sup> to members of municipal council. The contents must list the requirements of the *Safe Drinking Water Act, 2002*, the regulations, the system's approval and any order that the system failed to meet at any time during the reporting period covered, specify the duration of the failure, and the measures taken to correct the failure.

In addition, the report must include a summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly averages, maximum daily flows and daily instantaneous peak flows. The summary must be compared to the rated capacity and flows provided in the system's Municipal Drinking Water Licence.

The City of Brockville is the Owner of the Water Treatment Plant, trunk and local water distribution systems, and the City of Brockville is the Operating Authority for the Township of Elizabethtown-Kitley's water distribution system.

## 2.2 Summary of Regulatory Requirements

### Acts and Regulations

Regulated systems must meet the requirements of Ontario's *Safe Drinking Water Act, 2002* and its regulations. Most notably, the Drinking Water Systems Regulation sets out treatment and testing requirements for all categories of regulated water systems, including small non-municipal and seasonal operations.

### Safe Drinking Water Act, 2002

In the Part Two Report of the Walkerton Inquiry, Justice O'Connor recommended that the Ontario government enact a *Safe Drinking Water Act, 2002* to deal with matters related to treatment and distribution of drinking water. As articulated by Justice O'Connor, the purpose of the *Safe Drinking Water Act, 2002* is to gather in one place all legislation and regulations relating to the treatment and distribution of drinking water.

### Summary of Provincial Legislation Significant to Water Operations

| ACT   | O. Reg.        |
|---|----------------|
| <b>WATER OPPORTUNITIES and WATER CONSERVATION ACT</b>                         |                |
| ➤ Water Opportunities and Water Conservation Act, 2010                        | <b>Bill 72</b> |
| <b>CLEAN WATER ACT, 2006</b>  |                |
| ➤ Source Protection Areas and Regions   | O. Reg. 284/10 |
| ➤ Source Protection Committees  | O. Reg. 288/10 |
| ➤ Terms of Reference  | O. Reg. 287/07 |
| <b>SAFE DRINKING WATER ACT, 2002</b>  |                |
| ➤ Drinking Water Systems Regulation   | O. Reg. 170/03 |
| ➤ Certification of Drinking-Water System Operators and Water Quality Analysts | O. Reg. 128/04 |
| ➤ Drinking Water Testing Services - relating to laboratory licensing          | O. Reg. 248/03 |
| ➤ Schools, private schools and day nurseries                                  | O. Reg. 243/07 |
| ➤ Compliance and Enforcement Regulation                                       | O. Reg. 242/05 |

| <b>SAFE DRINKING WATER ACT, 2002 Continued</b>                 |                       |
|--|-----------------------|
| ➤ Ontario Drinking Water Quality Standards                     | O. Reg. 169/03        |
| ➤ Definitions of Words and Expressions Used in the Act         | O. Reg. 171/03        |
| ➤ Definition of Deficiency and Municipal Drinking Water System | O. Reg. 172/03        |
| ➤ Licensing of Municipal Drinking-Water Systems                | O. Reg. 188/07        |
| ➤ Financial Plans  | O. Reg. 453/07        |
| <b>ONTARIO WATER RESOURCES ACT</b>                             |                       |
| ➤ Licensing of Sewage Works Operators                          | O. Reg. 129/04        |
| ➤ Approval Exemption   | O. Reg. 525/98        |
| ➤ Wells  | R.R.O. 1990, Reg. 903 |
| ➤ Revoking Ontario Regulation 459/00                           | O. Reg. 175/03        |
| ➤ Revoking Ontario Regulation 505/01                           | O. Reg. 176/03        |
| ➤ Water Taking   | O. Reg. 387/04        |
| ➤ Charges for Industrial and Commercial Water Users            | O. Reg. 450/07        |
| <b>ENVIRONMENTAL PROTECTION ACT</b>                            |                       |
| ➤ Certificate of Approval Exemptions - Air                     | O. Reg. 524/98        |
| <b>ENVIRONMENTAL BILL OF RIGHTS ACT</b>                        |                       |
| ➤ Prescribing the Safe Drinking Water Act, 2002                | O. Reg. 257/03        |

### 3. ANNUAL WATER QUALITY SUMMARY FOR 2023

The City of Brockville's Water Systems Division is responsible for the Brockville Drinking Water System under O. Reg. 170/03 including water treatment plant, trunk water distribution system (elevated storage, reservoirs, booster stations) and local water distribution systems. Staff's primary responsibility is water treatment and distribution in compliance with all applicable legislation and municipal drinking water licenses and drinking water works permits. Routine water quality testing and continuous monitoring of water quality and quantity is conducted to ensure compliance. All data from SCADA, process control point data, in-house laboratory results and external laboratory results are all captured in a WaterTrax data management system.

#### 3.1 Water Quality Data

Raw and treated water is sampled and tested for chemical, physical and microbiological parameters in accordance with the requirements of O. Reg. 170/03 and individual municipal licenses and permits. Sampling is also conducted in the distribution system primarily for bacteriological indicators and evidence of sustained chlorine residuals. Enhanced sampling programs are also defined by the Water Systems Division, and testing procedures followed and where necessary submitted to external accredited laboratory for analysis. This level of water quality monitoring ensures public health and public confidence in the water supply.

The majority of analysis is conducted by an external accredited laboratory, with some specialized analysis contracted to other accredited laboratories. In accordance with Schedule 16 of O. Reg. 170/03, all required notifications of adverse water quality incidents are provided to the Spills Action Centre and Medical Officer of Health.

### Operational Testing:

The following table is a summary of the operational testing completed in 2023 (as per O. Reg. 170/03, Schedules 6 and 7).

| Parameter  | # of Grab Samples     | Results |      |      |
|--|-----------------------|---------|------|------|
|  |                       | MIN     | MAX  | AVG  |
| Turbidity – Raw (NTU)                                      | Continuous monitoring | 0.14    | 9.99 | 0.40 |
| Turbidity – Filter 1 (NTU)                                 | Continuous monitoring | 0.04    | 0.25 | 0.06 |
| Turbidity – Filter 2 (NTU)                                 | Continuous monitoring | 0.04    | 0.27 | 0.07 |
| Turbidity – Treated (NTU)                                  | Continuous monitoring | 0.03    | 2.27 | 0.06 |
| Chlorine – Pre Filter (mg/l)                               | Continuous monitoring | 0.00    | 3.00 | 0.38 |
| Chlorine – Reservoir (Main Plant) (mg/l)                   | Continuous monitoring | 1.65    | 2.32 | 2.04 |
| Chlorine – Plant Effluent (mg/l)                           | Continuous monitoring | 0.83    | 2.45 | 2.04 |
| Chlorine – Distribution System Parkedale Reservoir (mg/l)  | Continuous monitoring | 1.23    | 2.50 | 1.75 |
| Chlorine – Elizabethtown-Kitley Distribution System (mg/l) | 52                    | 1.12    | 1.64 | 1.35 |
| Fluoride – Plant Effluent (mg/l)                           | 365                   | 0.13    | 1.16 | 0.55 |
| UV Dosage (mJ/cm <sup>2</sup> )                            | Continuous monitoring | 0       | 3277 | 2.6  |
| UV Intensity (mW/cm <sup>2</sup> )                         | Continuous monitoring | 0       | 0    | n/a  |
| UV Transmittance (%)                                       | 365                   | 95      | 99.8 | 97.1 |

### Microbiological Testing:

Microbiological testing completed under the Schedule 10, 11 or 12 of O. Reg. 170/03 during 2023 reporting period.

| Sample Description: | Number of Samples | Range of E. Coli Or Fecal Results CFU/100ml |     | Range of Total Coliform Results CFU/100ml |     | Number of HPC Samples | Range of HPC Results CFU/ml |     |
|---------------------|-------------------|---|-----|---|-----|-----------------------|-----------------------------|-----|
|                     |                   | MIN   | MAX | MIN                                       | MAX |                       | MIN                         | MAX |
| Raw                 | 52                | 0   | 8   | 0   | 123 | 52                    | <10                         | 500 |
| Treated             | 52                | 0   | 0   | 0   | 0   | 52                    | <1                          | 20  |
| Distribution        | 510               | 0   | 0   | 0   | 0   | 356                   | <1                          | 480 |



### Chemical Testing:

The following Tables are a summary of the chemical testing completed in 2023 (as per O. Reg. 170/03, Schedule 13).

### Schedule 23

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results:**

| Parameter | Sample Date                 | Result Value | Unit of Measure | Exceeded the Standard | Exceeded Half the Standard |
|-----------|-----------------------------|--------------|-----------------|-----------------------|----------------------------|
| Antimony  | 2023-01-10                  | 0.0001       | mg/l            | No                    | No                         |
| Arsenic   | 2023-01-10                  | 0.0005       | mg/l            | No                    | No                         |
| Barium    | 2023-01-10                  | 0.022        | mg/l            | No                    | No                         |
| Boron     | 2023-01-10                  | 0.016        | mg/l            | No                    | No                         |
| Cadmium   | 2023-01-10                  | <0.000010    | mg/l            | No                    | No                         |
| Chromium  | 2023-01-10                  | <0.002       | mg/l            | No                    | No                         |
| Mercury   | 2023-01-10                  | <0.00002     | mg/l            | No                    | No                         |
| Selenium  | 2023-01-10                  | <0.001       | mg/l            | No                    | No                         |
| Sodium    | Jan. – Dec.<br>(12 samples) | 13.6*        | mg/l            | No                    | n/a                        |
| Uranium   | 2023-01-10                  | 0.00023      | mg/l            | No                    | No                         |
| Nitrite   | Quarterly<br>(4 samples)    | <0.1*        | mg/l            | No                    | No                         |
| Nitrate   | Quarterly<br>(4 samples)    | 0.25*        | mg/l            | No                    | No                         |

**\*average**

**n/a – not applicable**

## Schedule 24

### Summary of Organic parameters sampled during this reporting period or the most recent sample results:

| Parameter                                  | Sample Date | Result Value | Unit of Measure | Exceeded the Standard | Exceeded Half the Standard |
|--|-------------|--------------|-----------------|-----------------------|----------------------------|
| Alachlor                                   | 2023-01-17  | <0.3         | ug/l            | No                    | No                         |
| Atrazine + N-dealkylated metabolites       | 2023-01-17  | <0.5         | ug/l            | No                    | No                         |
| Azinphos-methyl                            | 2023-01-17  | <1           | ug/l            | No                    | No                         |
| Benzene                                    | 2023-01-10  | <0.5         | ug/l            | No                    | No                         |
| Benzo(a)pyrene                             | 2023-01-17  | <0.006       | ug/l            | No                    | No                         |
| Bromoxynil                                 | 2023-01-17  | <0.5         | ug/l            | No                    | No                         |
| Carbaryl                                   | 2023-01-17  | <3           | ug/l            | No                    | No                         |
| Carbofuran                                 | 2023-01-17  | <1           | ug/l            | No                    | No                         |
| Carbon Tetrachloride                       | 2023-01-10  | <0.2         | ug/l            | No                    | No                         |
| Chlorpyrifos                               | 2023-01-17  | <0.5         | ug/l            | No                    | No                         |
| Diazinon                                   | 2023-01-17  | <1           | ug/l            | No                    | No                         |
| Dicamba                                    | 2023-01-10  | <1           | ug/l            | No                    | No                         |
| 1,2-Dichlorobenzene                        | 2023-01-10  | <0.5         | ug/l            | No                    | No                         |
| 1,4-Dichlorobenzene                        | 2023-01-10  | <0.5         | ug/l            | No                    | No                         |
| 1,2-Dichloroethane                         | 2023-01-10  | <0.5         | ug/l            | No                    | No                         |
| 1,1-Dichloroethylene                       | 2023-01-10  | <0.5         | ug/l            | No                    | No                         |
| Dichloromethane                            | 2023-01-10  | <5           | ug/l            | No                    | No                         |
| 2-4 Dichlorophenol                         | 2023-01-17  | <0.2         | ug/l            | No                    | No                         |
| 2,4-Dichlorophenoxy acetic acid (2,4-D)    | 2023-01-10  | <1           | ug/l            | No                    | No                         |
| Diclofop-methyl                            | 2023-01-17  | <0.9         | ug/l            | No                    | No                         |
| Dimethoate                                 | 2023-01-17  | <1           | ug/l            | No                    | No                         |
| Diquat                                     | 2023-01-10  | <5           | ug/l            | No                    | No                         |
| Diuron                                     | 2023-01-17  | <5           | ug/l            | No                    | No                         |
| Glyphosate                                 | 2023-01-10  | <25          | ug/l            | No                    | No                         |
| Malathion                                  | 2023-01-17  | <5           | ug/l            | No                    | No                         |
| 2-Methyl-4-Chlorophenoxyacetic acid (MCPA) | 2023-01-10  | <10          | mg/l            | No                    | No                         |

## Brockville Drinking Water System Annual Water Quality Report 2023

| Parameter                                    | Sample Date                    | Result Value | Unit of Measure | Exceeded the Standard | Exceeded Half the Standard |
|--|--------------------------------|--------------|-----------------|-----------------------|----------------------------|
| Metolachlor                                  | 2023-01-17                     | <3           | ug/l            | No                    | No                         |
| Metribuzin                                   | 2023-01-17                     | <3           | ug/l            | No                    | No                         |
| Monochlorobenzene                            | 2023-01-10                     | <0.5         | ug/l            | No                    | No                         |
| Paraquat                                     | 2023-01-10                     | <1           | ug/l            | No                    | No                         |
| Pentachlorophenol                            | 2023-01-17                     | <0.2         | ug/l            | No                    | No                         |
| Phorate                                      | 2023-01-17                     | <0.3         | ug/l            | No                    | No                         |
| Picloram                                     | 2023-01-10                     | <5           | ug/l            | No                    | No                         |
| Polychlorinated Biphenyls(PCB)               | 2023-01-10                     | <0.05        | ug/l            | No                    | No                         |
| Prometryne                                   | 2023-01-17                     | <0.1         | ug/l            | No                    | No                         |
| Simazine                                     | 2023-01-17                     | <0.5         | ug/l            | No                    | No                         |
| THM<br>(NOTE: shows latest annual average)   | Quarterly<br>(min) (4 samples) | 33.0*        | ug/l            | No                    | No                         |
| HAA's<br>(NOTE: shows latest annual average) | Quarterly<br>(min) (4 samples) | 18.1*        | ug/l            | No                    | No                         |
| Terbufos                                     | 2023-01-17                     | <0.5         | ug/l            | No                    | No                         |
| Tetrachloroethylene                          | 2023-01-10                     | <0.5         | ug/l            | No                    | No                         |
| 2,3,4,6-Tetrachlorophenol                    | 2023-01-17                     | <0.2         | ug/l            | No                    | No                         |
| Triallate                                    | 2023-01-17                     | <10          | ug/l            | No                    | No                         |
| Trichloroethylene                            | 2023-01-10                     | <0.5         | ug/l            | No                    | No                         |
| 2,4,6-Trichlorophenol                        | 2023-01-17                     | <0.2         | ug/l            | No                    | No                         |
| Trifluralin                                  | 2023-01-17                     | <0.5         | ug/l            | No                    | No                         |
| Vinyl Chloride                               | 2023-01-10                     | <0.2         | ug/l            | No                    | No                         |

**\*average**

## LEAD SAMPLING:

### Brockville Drinking Water System (Lead Sampling Exemption for plumbing only)

| Sampling Period – Winter (December 15 <sup>th</sup> to April 15 <sup>th</sup> ) | Plumbing | Distribution |
|---|----------|--------------|
| Number of individual samples  | N/A      | 4            |
| Number of sample points (locations)   | N/A      | 4            |
| Number of individual sample exceedances   | N/A      | 0            |
| Number of sample points with an exceedance during the period                    | N/A      | 0            |
| Percentage of sample points with an exceedance                                  | N/A      | 0            |
| Is the system required to have a Corrosion Control Plan prepared?               | NO       | NO           |
| Do the reduced sampling & frequency requirements apply to the system?           | N/A      | YES          |
| Do the plumbing sample exemptions apply to the system?                          | YES      | N/A          |

| Sampling Period - Summer (June 15 <sup>th</sup> to October 15 <sup>th</sup> ) | Plumbing | Distribution |
|---|----------|--------------|
| Number of individual samples  | N/A      | 4            |
| Number of sample points (locations)   | N/A      | 4            |
| Number of individual sample exceedances                                       | N/A      | 0            |
| Number of sample points with an exceedance during the period                  | N/A      | 0            |
| Percentage of sample points with an exceedance                                | N/A      | 0            |
| Is the system required to have a Corrosion Control Plan prepared?             | NO       | NO           |
| Do the reduced sampling & frequency requirements apply to the system?         | N/A      | YES          |
| Do the plumbing sample exemptions apply to the system?                        | YES      | N/A          |

Elizabethtown-Kitley Distribution System (Lead Sampling Exemption for plumbing only)

| Sampling Period – Winter (December 15 <sup>th</sup> to April 15 <sup>th</sup> ) | Plumbing                          | Distribution |
|---|-----------------------------------|--------------|
| Number of individual samples  | (Lead Sampling Regulatory Relief) | 2            |
| Number of sample points (locations)   | N/A                               | 2            |
| Number of individual sample exceedances   | N/A                               | 0            |
| Number of sample points with an exceedance during the period                    | N/A                               | 0            |
| Percentage of sample points with an exceedance                                  | N/A                               | 0            |
| Is the system required to have a Corrosion Control Plan prepared?               | NO                                | NO           |
| Do the reduced sampling & frequency requirements apply to the system?           | N/A                               | YES          |
| Do the plumbing sample exemptions apply to the system?                          | YES                               | N/A          |

| Sampling Period - Summer (June 15 <sup>th</sup> to October 15 <sup>th</sup> ) | Plumbing                          | Distribution |
|---|-----------------------------------|--------------|
| Number of individual samples  | (Lead Sampling Regulatory Relief) | 2            |
| Number of sample points (locations)   | N/A                               | 2            |
| Number of individual sample exceedances                                       | N/A                               | 0            |
| Number of sample points with an exceedance during the period                  | N/A                               | 0            |
| Percentage of sample points with an exceedance                                | N/A                               | 0            |
| Is the system required to have a Corrosion Control Plan prepared?             | NO                                | NO           |
| Do the reduced sampling & frequency requirements apply to the system?         | N/A                               | YES          |
| Do the plumbing sample exemptions apply to the system?                        | YES                               | N/A          |

## 4. BROCKVILLE DRINKING WATER SYSTEM

### 4.1 Water System Description

|                                   |                                  |
|-----------------------------------|----------------------------------|
| Drinking-Water System Number:     | 220001263                        |
| Drinking-Water System Name:       | Brockville Drinking Water System |
| Drinking-Water System Owner:      | City of Brockville               |
| Accredited Operating Authority:   | City of Brockville               |
| Municipal Drinking Water Licence: | 152-101                          |
| Drinking Water Works Permit:      | 152-201                          |
| Permit To Take Water:             | 8577-5ZCP45                      |
| Drinking-Water System Category:   | Large Municipal                  |
| Design Capacity:                  | 36.4 ML/D                        |
| Treatment:                        | Direct Filtration Class III      |
| Local Distribution:               | Class II                         |
| Trunk Distribution:               | Class III                        |
| Source Water:                     | St Lawrence River                |
| Population Served:                | 22,000                           |

### Connected Drinking-Water Systems:

|                                   |  |
|-----------------------------------|--|
| Drinking-Water System Number:     | 260007777                                |
| Drinking-Water System Name:       | Elizabethtown-Kitley Distribution System |
| Drinking-Water System Owner:      | Township of Elizabethtown-Kitley         |
| Accredited Operating Authority:   | City of Brockville                       |
| Municipal Drinking Water Licence: | 257-101                                  |
| Drinking Water Works Permit:      | 257-201                                  |
| Drinking-Water System Category:   | Large Municipal Class I                  |
| Water Source:                     | City of Brockville DWS                   |
| Population Served:                | 350                                      |

#### 4.1.1 Water Treatment Plant

The City of Brockville's Water Treatment Plant is a Class III direct filtration facility located at 20 Rivers Avenue, located on the St. Lawrence River and serves the City of Brockville (population 22,000), and a portion of the Township of Elizabethtown-Kitley (population 350).

A 900 mm raw water intake pipe equipped with zebra mussel control lies on the bottom of the St. Lawrence River extending 300 meters offshore at a depth of 10.5 meters. The treatment process has a design maximum flow rate of 36.4 ML/d and is composed of a number of sub-units:

- low lift pumping station
- coagulation and flocculation using polyaluminum chloride (PAC)
- pre- and post-filter disinfection with chlorine gas
- two granular activated carbon filters
- fluoride addition
- treated water reservoir and high lift pumping station
- final treated water UV disinfection and additional chlorination

#### 4.1.2 Treatment Chemicals Used

All chemicals used in the operation of the drinking water system meets all applicable standards set by both the American Water Works Association ("AWWA") and the American National Standards Institute ("ANSI") safety criteria standards NSF/60 and NSF/61

| Chemical  | Application  | Supplier               |
|---|--|------------------------|
| Chlorine Gas  | Pre Filter, Post Filter, Plant Effluent (Primary Disinfection) | Brenntag Canada        |
| Poly Aluminum Chloride XL-6 (SternPAC)<br>PAX XL-1900 (ACH) | Pre Filter (Coagulant)   | Kemira Water Solutions |
| Hydrofluorosilicic acid (HFSA)                              | Plant Effluent (Fluoride)                                      | Brenntag Canada        |

#### 4.1.3 Water Distribution System – Trunk and Local Systems

The Water Distribution System is separated into a Class III Trunk Water Distribution System (Certificate #3811) and a Class II Local Water Distribution System (Certificate #2193).

The distribution is comprised of 3 distinct pressure zones and consists of underground pipes ranging in size from 100 mm to 600 mm in diameter, made of a variety of materials including cast iron, ductile iron, poly vinyl chloride (PVC), concrete, steel, high density polyethylene (HDPE), and asbestos cement. There are approximately 8,400 service connections, 940 fire hydrants and 2,800 valves. Several treated water storage facilities and booster stations are located throughout the system as indicated below.

➤ Trunk Feeder Main & Local Distribution Systems

600 mm single trunk feeder main from the WTP to the Church Street/Perth Street area where flow splits between the Water Tower and the Local and Trunk distribution systems.

➤ Water Booster Stations

There are three (3) booster pump stations (First Avenue., Sunset Boulevard., Parkedale Avenue.) within the distribution system. These booster stations utilize pumps to ensure consistent pressure throughout the system.

➤ Perth Street Elevated Storage Tank (Water Tower)

The most visible feature of the distribution system is the 2,270 m<sup>3</sup> (500,000 IG) elevated storage tank located on Perth St in Zone 1. It is a single cell, steel, non-baffled treated water storage tank.

➤ Parkedale Avenue Reservoir Booster Station

The Parkedale Avenue Reservoir Booster Station is a 7,600 m<sup>3</sup> capacity reservoir at-grade, single cell, concrete, non-baffled, treated water reservoir. The station services two geographical areas. Zone 1 is the area South of Highway 401, and Zone 2 is the area North of Highway 401.

Zone 1 and Zone 2 booster stations are located on this site and assist in maintaining system pressures within the 2 zones.

➤ First Avenue Booster Station

The First Avenue Booster Station located on First Avenue services Zone 3. Zone 3 is defined by the boundary of First Avenue to the West, King Street East to the South, Broadway Avenue to the North, and Oxford Avenue to the East.

➤ Sunset Boulevard Booster Station

This booster station is located within a below grade pump chamber on Sunset Boulevard and provides consistent pressure locally to Sunset Boulevard and Hollywood Place

## 4.2 2023 Flow Summary

In 2023 the maximum or peak instantaneous raw water flow recorded was 34.168 ML/day (23,728 L/min) which occurred on July 10<sup>th</sup>, 2023 and was below the permitted maximum amount of 36.400 ML/day (25,278 L/min). The maximum volume of raw water taken on any single day was 14.884 ML which occurred on July 10<sup>th</sup>, 2023, and was also below the permitted maximum of 36.400 ML/d.

The annual average daily raw water volume to the WTP was 9.859 ML/day or 27.1% of its maximum approved treatment capacity of 36.4 ML/day.



## Maximum Permitted Water Taking (PTTW) – WTP

| Condition:                               | Maximum Permitted Water Taking |
|--|--------------------------------|
| Maximum Amount of Water Taken per Minute | 25,278 (L/min)                 |
| Maximum Amount of Water Taken per Day    | 36.4 (ML/d)                    |

The Permit to Take Water specifies the maximum flow into individual treatment systems as indicated below.

## Maximum Flow to Treatment System – WTP

| Treatment System/Stage: | Maximum Flow Rate (ML/d) |
|-------------------------|--------------------------|
| GAC Filters – Flow      | 19.6 each                |
| UV Disinfection System  | 36.4 each                |

The summary of the volume of water taken daily and the flows of the water supplied during the 2023 calendar year is provided in **Appendix C** and includes 2023 flow data and historical flow of past years of pumping at the WTP.

The historical total plant distributed volume is also displayed in **Appendix C**. The total annual plant distributed volume for 2023 is 3.27% more than the total annual plant distributed volume from 2022. This information is provided for interest and to evaluate the treatment system trends over time in order to prepare for any future improvements required to meet this demand.

### 4.3 Adverse Water Quality Incident (AWQI) Test Results

In accordance with Schedule 16 of O. Reg. 170/03, all required notifications of adverse water quality incidents were provided to the Medical Officer of Health (MOH) and the Spills Action Centre (SAC). In 2023 there were five (5) Adverse Water Quality Incidents to report.

Brockville Drinking Water System Annual Water Quality Report 2023

| AWQI Incident Date               | Parameter  | Result                                      | Corrective Action  | Corrective Action Date |
|----------------------------------|--|---|--|------------------------|
| AWQI # 162132<br>June 7, 2023    | Operational<br>Distribution System pressure                          | < 20 psi                                    | <ul style="list-style-type: none"> <li>-Took free Cl2 residual at first Avenue booster station at 17:58 on 2023/06/07. 1.70 free Cl2.</li> <li>-Took free Cl2 residual from H6 (in west of break site) at 19:13 on 2023/06/07. 1.98 free Cl2.</li> <li>Flushed large debris into hole before repairs completed. 01:00 on 2023/06/08.</li> <li>-Bacteriological sample from H471 (east of break site - flushed through break/repair area) at 09:45 on 2023/06/08.</li> </ul>  | June 7-8, 2023         |
| AWQI # 162428<br>July 5, 2023    | Operational<br>Filter Turbidity                                      | unknown                                     | <ul style="list-style-type: none"> <li>-Provided copies of trending data and Historian log sheet of filter 1 and Filter operation from July, 2, 2023 to July, 5, 2023</li> <li>-Operation of filters 1 and 2 is very similar and historically no issues with either filter achieving adverse state.</li> <li>- Manual turbidity grab at 5:51pm showing not in adverse state.</li> <li>- Chlorine residuals maintained normal throughout treatment process and distribution system. Verified by chain of custody and certificate of analysis for weekly bacteriological samples collected July, 4, 2023 and weekly distribution samples collected July, 5, 2023.</li> <li>- Experienced no loss of CT.</li> <li>No further actions required by MOH</li> </ul> | July 5, 2023           |
| AWQI # 162796<br>July 26, 2023   | Microbiological<br>No data, overgrown with non-target bacteria       | No data, overgrown with non-target bacteria | <ul style="list-style-type: none"> <li>-Re-sample taken from site of adverse result.</li> <li>- Flush and sample taken from hydrants on either side of original adverse location (H889 and H919).</li> </ul>   | July 25-26, 2023       |
| AWQI # 163750<br>October 9, 2023 | Observations of Improperly disinfected water directed to water users | n/a   | <ul style="list-style-type: none"> <li>-Pipe was flushed into excavation, hydrant out front of building was flushed, service line was flushed outside of building, taps were flushed inside of building.</li> <li>-Pipe was flushed into open excavation before being capped.</li> <li>Service was flushed prior to being connected to building and lines were flushed inside building once service was connected.</li> <li>-Notices posted throughout building advising not to consume water until sampling is complete and favorable results are received.</li> <li>-Bacteriological sampling from service line as well as from multiple points inside building October 10, 2023.</li> <li>-bacteriological sampling as per the MOH direction</li> </ul>   | October 9-10, 2023     |

| AWQI Incident Date                | Parameter  | Result | Corrective Action  | Corrective Action Date |
|-----------------------------------|--|--------|--|------------------------|
| AWQI # 163816<br>October 16, 2023 | Observations of Improperly disinfected water directed to water users | n/a    | <ul style="list-style-type: none"> <li>-Sample 1 taken 6:30pm 10/16/2023, sample 2 taken 10/18/2023.</li> <li>-Free Cl<sub>2</sub> was restored once flushing was able to be completed. 1.93 Free Cl<sub>2</sub>, 2.20 total Cl<sub>2</sub>.</li> <li>-Flushed once repairs were completed.</li> <li>-Door knockers/notices were handed to residents prior to repair being completed, and prior to water being turned back on.</li> <li>-Provided bottled water until favorable results were received.</li> <li>-Hydrant (H24) nearest affected homes was flushed June 22, 2023 had free Cl<sub>2</sub> of 1.87 mg/L.</li> </ul> | October 16-18, 2023    |

#### 4.4 Operator Certification

The *Certification of Drinking-Water System Operators and Water Quality Analysts* (O. Reg. 128/04) requires owners to ensure that every operator employed in the facility holds a Licence applicable to that type of facility. All operators in the Water Systems Division hold the required certifications for treatment and distribution.

#### 4.5 Capital Program

The 2023 Capital Program can be found in **Appendix B** of this Report. All works are subject to the annual budget process and approval by Council. A 30 Year Capital Replacement Equipment Plan has been developed that includes an extensive breakdown of all capital equipment that requires allocated funds for refurbishment or replacement. This is not included in the Annual Summary Report but can be made available upon request.

## 5. TOWNSHIP OF ELIZABETHTOWN-KITLEY WATER DISTRIBUTION SYSTEM

### 5.1 Water System Description

The City of Brockville provides treated water from its Water Treatment Plant to the Elizabethtown-Kitley Class I Water Distribution System (Certificate# 3536) west of the City. This is facilitated through a 14 kilometer water main that extends along County Road #2 to the Country Club, through a meter chamber and associated appurtenances. This distribution system services approximately 350 residential customers. This system was installed in 1998 by the Ministry of Transportation and the Ontario Clean Water Agency and turned over to the Township of Elizabethtown-Kitley in 1999.

A booster station at Lily Bay provides for increased pressure only. The Township Fire Department is aware of this operational constraint and does not use the distribution system for firefighting or training purposes. An automated flushing station at the end of the service line is required to maintain free chlorine residual above the regulated minimum level of 0.20 mg/L. City Staff operate and maintain this system on behalf of the Township as the Operating Authority.

### Township of Elizabethtown-Kitley

|                                   |  |
|-----------------------------------|--|
| Drinking-Water System Number:     | 260007777                                |
| Drinking-Water System Name:       | Elizabethtown-Kitley Distribution System |
| Drinking-Water System Owner:      | Township of Elizabethtown-Kitley         |
| Accredited Operating Authority:   | City of Brockville                       |
| Municipal Drinking Water Licence: | 257-101                                  |
| Drinking Water Works Permit:      | 257-201                                  |
| Drinking-Water System Category:   | Large Municipal Class 1                  |
| Water Source:                     | City of Brockville DWS                   |
| Population Served:                | 350                                      |

### 5.2 Adverse Water Quality Incident (AWQI) Test Results

No adverse water quality incidents reported to SAC in 2023 for the Township of Elizabethtown-Kitley Water Distribution System.

### 5.3 Historical Flow Results

A summary of the volume of water taken daily and the flows of the water supplied during the 2023 calendar year is provided in **Appendix C**.

The historical flow is also displayed in **Appendix C**. The total flow for 2023 is 18.8% less than the total flow from 2022. This information is provided for interest and to evaluate the system flow trends over time to prepare for any future improvements required to meet this demand.

## **6. CONCLUSION**

The City of Brockville serves approximately 22,000 residents and about 350 residents in the Township of Elizabethtown-Kitley. One of the City's most important responsibilities is to protect public health by providing its residents with clean, safe drinking water. Routine water quality testing and continuous monitoring of the water quality and quantity is completed by City Staff at the Water Treatment Plant and throughout the distribution systems to demonstrate that the City consistently meets or exceeds the standards set by the MECP.

In Ontario, water taking, treatment and distribution are governed by several Acts and Regulations. This report fulfills the reporting requirements of the Drinking Water System Regulation (O. Reg. 170/03) made under the Safe Drinking Water Act for all of the municipal drinking water treatment systems in the City of Brockville and the Township of Elizabethtown-Kitley and covers the period from January 1<sup>st</sup> to December 31<sup>st</sup> 2023. As required under this same regulation, the report is prepared prior to March 31<sup>st</sup> and is filed for review by both the City of Brockville's and Elizabethtown-Kitley's municipal council. Copies of the report are also on hand at the Public Library, the Customer Service Office at City Hall, the Water Treatment Plant at 20 Rivers Avenue, Brockville and the Township of Elizabethtown-Kitley's Municipal Office at 6544 New Dublin Road, Addison.


The contents of this report highlight the requirements of the Safe Drinking Water Act, the regulations, and the systems' approval including any reportable events and the corresponding corrective actions undertaken in 2023. In addition, the report also includes a summary of the quantities and flow rates of the water supplied during the calendar year, including monthly averages, maximum daily flows, and daily instantaneous peak flow rates. The summaries are compared to the rated capacity and flow rates in the system approvals.

The Water Systems Division has taken all necessary steps to comply with all regulatory requirements in the production and distribution of safe drinking water and to conform to the requirements of implementing and maintaining a Drinking Water Quality Management System. The dedication and commitment of all Water Systems Staff ensures a safe reliable drinking water supply to consumers of the City of Brockville and a portion of the Township of Elizabethtown-Kitley.

## **7. KEY CONTACTS**

Peter Raabe, P. Eng.  
Director of Engineering and Infrastructure  
Phone: 613-342-8772 ext. 3257  
Fax: 613-342-5035  
Email: [praabe@brockville.com](mailto:praabe@brockville.com)

Clay Sluytman  
Supervisor – Water Systems  
Phone: 613-342-8772 ext. 5512  
Email: [csluytman@brockville.com](mailto:csluytman@brockville.com)



## Appendix B

### 2023 PROPOSED CAPITAL PROGRAM

|                      |  |           |   |                      |                  |
|----------------------|--|-----------|---|----------------------|------------------|
| <u>PROJECT NAME:</u> | Water Equipment/Construction - Proposed Maintenance and New Capital  |           |   | <u>YEAR PROPOSED</u> | 2023             |
| <u>LOCATION:</u>     | Brockville Water Treatment Plant, Distribution System, Trunk Distribution System and Booster Stations  |           |   |                      |                  |
| <u>SCOPE:</u>        | Provides for the capital needs of the Water Treatment Plant, Distribution System, Trunk Distribution System and Booster Stations.<br>Funding is provided through water revenues. |           |   |                      |                  |
| <u>PROJECT ID:</u>   | <u>Priority</u>  | <u>GL</u> |   |                      | <u>Budget</u>    |
|                      |  |           | <b>WATER SYSTEMS - PROPOSED CAPITAL PROJECTS</b>      |                      |                  |
|                      | 1  |           | WTP Laboratory Fixture Replacement                    |                      | 15,000           |
|                      | 2  |           | Lowlift Pumphouse - Exterior Condition Assessment     |                      | 7,500            |
|                      | 3  |           | Lowlift Pumphouse - Window and Door Replacements      |                      | 15,000           |
|                      | 4  |           | WTP interior / exterior lighting replacement          |                      | 10,000           |
|                      | 5  |           | Highlift MCC HVAC Upgrades                            |                      | 35,000           |
|                      | 6  |           | PLC Replacements (4x SLC/505)                         |                      | 80,000           |
|                      | 7  |           | Pre-Engineering of replacement UV Disinfection System |                      | 20,000           |
|                      | 8  |           | Lowlift Pump #1 Overhaul Maintenance                  |                      | 22,500           |
|                      | 9  |           | Parkedale Zone 2 Pump 2 VFD                           |                      | 45,000           |
|                      | 10   |           | Parkedale - Lane Modifications                        |                      | 30,000           |
|                      | 11   |           | First Avenue Booster Station - VFD and Metering       |                      | 65,000           |
|                      | 12   |           | Overhead Tank - Strip and Recoat                      |                      | 578,232          |
|                      | 13   |           | Overhead Tank - Safety Upgrades                       |                      | 50,000           |
|                      | 14   |           | Backflow Prevention Monitoring Program                |                      | 15,000           |
|                      | 15   |           | Front Avenue Watermain Replacement                    |                      | 525,000          |
|                      | 16   |           | Water Meter Replacement Program (10% of meters /year) |                      | 50,000           |
|                      | 17   |           | Bulk Water Station                                    |                      | 70,000           |
|                      | 18   |           | Unit 21510 Replacement (3/4 ton)                      |                      | 70,000           |
|                      |  |           |   |                      | <b>1,703,232</b> |

PREPARED BY (PROJECT MANAGER):

Craig Drake

DATE:

01-Dec-22


**BROCKVILLE WATER SYSTEMS ANNUAL TREATED WATER VOLUME REPORT 2023**

| <u>Month</u> | <u>WTP Raw<br/>Avg Daily<br/>Volume<br/>(ML)</u> | <u>WTP Raw<br/>Max Daily<br/>Volume<br/>(ML)</u> | <u>WTP Raw<br/>Peak Flow<br/>(ML/day)</u> | <u>WTP Raw<br/>Total<br/>Monthly<br/>Volume<br/>(ML)</u> | <u>WTP<br/>Treated<br/>Avg<br/>Daily<br/>Volume<br/>(ML)</u> | <u>WTP<br/>Treated<br/>Max<br/>Daily<br/>Volume<br/>(ML)</u> | <u>Rated<br/>Capacity<br/>(ML/day)</u> | <u>Rated<br/>Flow<br/>Capacity<br/>(%)</u> | <u>WTP<br/>Treated<br/>Total<br/>Monthly<br/>Volume<br/>(ML)</u> |
|--------------|--|--|---|--|--|--|--|--|--|
| January      | 9.050  | 9.427  | 16.980                                    | 280.554  | 8.504  | 9.427  | 36.400                                 | 24.8%                                      | 263.614  |
| February     | 9.207  | 9.932  | 17.200                                    | 257.784  | 8.651  | 9.426  | 36.400                                 | 25.9%                                      | 242.224  |
| March        | 9.539  | 11.479   | 17.475                                    | 295.711  | 8.970  | 10.968   | 36.400                                 | 30.1%                                      | 278.068  |
| April        | 9.343  | 10.326   | 16.962                                    | 280.291  | 8.768  | 9.746  | 36.400                                 | 26.8%                                      | 263.042  |
| May          | 9.928  | 12.508   | 24.265                                    | 307.760  | 9.360  | 11.722   | 36.400                                 | 32.2%                                      | 290.148  |
| June         | 10.773   | 12.250   | 24.994                                    | 323.176  | 10.105   | 11.782   | 36.400                                 | 32.4%                                      | 303.153  |
| July         | 11.451   | 14.884   | 34.168                                    | 354.980  | 10.710   | 13.884   | 36.400                                 | 38.1%                                      | 332.014  |
| August       | 10.513   | 11.662   | 21.747                                    | 325.903  | 9.887  | 11.144   | 36.400                                 | 30.6%                                      | 306.507  |
| September    | 10.321   | 11.907   | 23.679                                    | 309.630  | 9.716  | 10.988   | 36.400                                 | 30.2%                                      | 291.482  |
| October      | 9.836  | 12.104   | 25.446                                    | 304.912  | 9.284  | 11.310   | 36.400                                 | 31.1%                                      | 287.796  |
| November     | 9.051  | 9.701  | 17.182                                    | 271.541  | 8.643  | 9.236  | 36.400                                 | 25.4%                                      | 259.278  |
| December     | 9.234  | 9.839  | 20.835                                    | 286.257  | 8.709  | 9.298  | 36.400                                 | 25.5%                                      | 269.988  |
| TOTAL        |  |  |   | 3,598.499  |  |  |  |  | 3,387.314  |

**BROCKVILLE WATER SYSTEMS HISTORICAL ANNUAL TREATED WATER VOLUMES**

| <u>Year</u> | <u>Annual Volume<br/>(ML)</u> | <u>Year</u> | <u>Annual Volume<br/>(ML)</u> |
|-------------|-------------------------------|-------------|-------------------------------|
| 1963        | 5,468.128                     | 1995        | 5,467.001                     |
| 1964        | 5,792.558                     | 1996        | 5,148.340                     |
| 1965        | 7,026.093                     | 1997        | 5,698.474                     |
| 1966        | 6,652.020                     | 1998        | 5,519.157                     |
| 1967        | 6,531.729                     | 1999        | 5,631.225                     |
| 1968        | 6,302.901                     | 2000        | 5,565.808                     |
| 1969        | 6,174.018                     | 2001        | 5,726.410                     |
| 1970        | 6,447.978                     | 2002        | 5,032.500                     |
| 1971        | 6,246.122                     | 2003        | 5,117.740                     |
| 1972        | 5,876.886                     | 2004        | 5,238.190                     |
| 1973        | 6,179.755                     | 2005        | 5,625.869                     |
| 1974        | 6,552.608                     | 2006        | 5,308.800                     |
| 1975        | 7,049.823                     | 2007        | 5,189.831                     |
| 1976        | 6,157.384                     | 2008        | 4,715.116                     |
| 1977        | 5,862.139                     | 2009        | 4,332.102                     |
| 1978        | 6,283.413                     | 2010        | 4,128.747                     |
| 1979        | 6,340.110                     | 2011        | 4,291.115                     |
| 1980        | 6,905.996                     | 2012        | 4,213.592                     |
| 1981        | 6,324.999                     | 2013        | 3,815.746                     |
| 1982        | 5,685.995                     | 2014        | 3,822.724                     |
| 1983        | 6,119.997                     | 2015        | 3,972.362                     |
| 1984        | 5,894.998                     | 2016        | 3,744.720                     |
| 1985        | 5,451.999                     | 2017        | 3,595.184                     |
| 1986        | 5,780.998                     | 2018        | 3,889.242                     |
| 1987        | 5,515.998                     | 2019        | 3,753.200                     |
| 1988        | 5,319.997                     | 2020        | 3,641.936                     |
| 1989        | 6,034.455                     | 2021        | 3,615.261                     |
| 1990        | 5,064.771                     | 2022        | 3,280.074                     |
| 1991        | 5,297.094                     | 2023        | 3,387.314                     |
| 1992        | 5,037.999                     |             |                               |
| 1993        | 5,013.019                     |             |                               |
| 1994        | 5,548.256                     |             |                               |






### **ELIZABETHTOWN-KITLEY WATER DISTRIBUTION ANNUAL TREATED WATER VOLUME REPORT 2023**

| <b><u>Month</u></b> | <b><u>Avg Daily Volume (m3)</u></b> | <b><u>Max Daily Volume (m3)</u></b> | <b><u>Max Flow (L/min)</u></b> | <b><u>Total Volume (m3)</u></b> |
|---------------------|-------------------------------------|-------------------------------------|--------------------------------|---------------------------------|
| January             | 148                                 | 182                                 | 565                            | 4,581                           |
| February            | 143                                 | 181                                 | 557                            | 4,010                           |
| March               | 147                                 | 181                                 | 606                            | 4,544                           |
| April               | 160                                 | 238                                 | 2,834                          | 4,807                           |
| May                 | 189                                 | 298                                 | 721                            | 5,845                           |
| June                | 199                                 | 302                                 | 811                            | 5,978                           |
| July                | 206                                 | 256                                 | 772                            | 6,397                           |
| August              | 174                                 | 205                                 | 701                            | 5,398                           |
| September           | 182                                 | 245                                 | 643                            | 5,455                           |
| October             | 173                                 | 261                                 | 597                            | 5,371                           |
| November            | 136                                 | 158                                 | 594                            | 4,087                           |
| December            | 138                                 | 180                                 | 560                            | 4,269                           |
| <b>TOTAL</b>        |                                     |                                     |                                | <b>60,742</b>                   |

### **ELIZABETHTOWN- KITLEY WATER DISTRIBUTION HISTORICAL ANNUAL TREATED WATER VOLUME**

| <b><u>Year</u></b> | <b><u>Total Annual Volume (m3)</u></b> | <b><u>Year</u></b> | <b><u>Total Annual Volume (m3)</u></b> |
|--------------------|--|--------------------|--|
| 2004               | 81,913                                 | 2014               | 62,873                                 |
| 2005               | 101,402                                | 2015               | 52,646                                 |
| 2006               | 99,254                                 | 2016               | 47,965                                 |
| 2007               | 113,068                                | 2017               | 40,185                                 |
| 2008               | 128,460                                | 2018               | 49,216                                 |
| 2009               | 98,782                                 | 2019               | 55,753                                 |
| 2010               | 95,876                                 | 2020               | 54,968                                 |
| 2011               | 74,052                                 | 2021               | 59,876                                 |
| 2012               | 76,372                                 | 2022               | 74,804                                 |
| 2013               | 71,552                                 | 2023               | 60,742                                 |





## 2023 WATER LOSS REPORT

|   |  |                                |
|---|--|--------------------------------|
| <b>WATER TREATMENT PLANT - DISTRIBUTION TOTAL</b>       |  | <b>3,387,314 m<sup>3</sup></b> |
| <b>Water Sold to Customers</b>                          |  |                                |
| Residential   |  | 1,365,967 m <sup>3</sup>       |
| Industrial  |  | 1,526,180 m <sup>3</sup>       |
| Sales to Elizabethtown-Kitley (East of Brockville, BCC) |  | 53,779 m <sup>3</sup>          |
| Sales to Elizabethtown-Kitley (West of Brockville)      |  | 41,561 m <sup>3</sup>          |
| <b>TOTAL BILLED WATER</b>                               |  | <b>2,987,487 m<sup>3</sup></b> |
| <b>Total Non-Revenue Water (NRW)</b>                    |  | <b>399,827 m<sup>3</sup></b>   |
|   |  | <b>11.80 %</b>                 |
| <b>NRW Sources Accounted For</b>                        |  |                                |
| Flat Rate Water Users                                   |  | 25,900 m <sup>3</sup>          |
| Industrial Fire Flow Testing                            |  | 5,000 m <sup>3</sup>           |
| Chlorinator Flow/Mechanical Seals                       |  | 18,355 m <sup>3</sup>          |
| Watermain Breaks/Service Leaks                          |  | 42,244 m <sup>3</sup>          |
| Anti-Freeze Taps  |  | 51,660 m <sup>3</sup>          |
| Fire Fighting and Training                              |  | 8,665 m <sup>3</sup>           |
| Hydrant Fire Flow Testing and Flushing                  |  | 1,354 m <sup>3</sup>           |
| Flushing Stations                                       |  | 158,122 m <sup>3</sup>         |
| Parks and Recreation Water Use                          |  | 10,453 m <sup>3</sup>          |
| <b>TOTAL</b>  |  | <b>321,753 m<sup>3</sup></b>   |
|   |  | <b>9.50 %</b>                  |
| <b>TOTAL Unaccounted NRW</b>                            |  | <b>78,074 m<sup>3</sup></b>    |
|   |  | <b>2.30 %</b>                  |

Last Reviewed: Feb 5, 2024

By: S. Allen



## 2023 WATER LOSS REPORT

|                                      |   |
|--------------------------------------|---|
| <b>TOTAL METERED WATER</b>           | <b>60,742 m<sup>3</sup></b>                   |
| <b>TOTAL BILLED WATER</b>            | <b>41,561 m<sup>3</sup></b>                   |
| <b>Total Non-Revenue Water (NRW)</b> | <b>19,181 m<sup>3</sup></b><br>31.58 %        |
| <b>NRW Sources Accounted For</b>     |   |
| Watermain Breaks                     | 5,753 m <sup>3</sup>                          |
| Hydrant Fire Flow Testing            | 15 m <sup>3</sup>                             |
| Flushing Stations                    | 2,436 m <sup>3</sup>                          |
| <b>TOTAL</b>                         | <b>8,203 m<sup>3</sup></b><br>13.5%           |
| <b>TOTAL LOST WATER</b>              | <b>10,978 m<sup>3</sup></b><br><b>18.07 %</b> |

Last Reviewed: Feb 28, 2024

By: S. Allen